

**From:** Kaye Adams [<mailto:kaye.adams@westsussex.gov.uk>] **On Behalf Of** Business Fire Safety  
**Sent:** 06 August 2019 12:01  
**To:** Guest, Jackie <[Jackie.Guest@crawley.gov.uk](mailto:Jackie.Guest@crawley.gov.uk)>  
**Subject:** E0615B Deja Vu Bar

LICENSING ACT 2003

Thank you for the information.

The Fire Authority have no objection to the application for a review of the Premises Licence in respect of the above premises.

A inspection was carried out by Hannah Boyns in September 2018 following some multi agency visits in Crawley the same month. Emergency lights weren't working and the fire extinguishers were out of date.

A letter was sent to Daryl the manager (and copied to yourselves) detailing the issues that needed rectifying.

Should you require any further advice or assistance please do not hesitate to contact the Protection Team at the above address.

Please can you acknowledge receipt - thank you

***We value your feedback. Please have your say [here](#)***

[Click here for Feedback Form](#)

---

**Kaye Adams Inspecting Officer- Business Fire Safety. West Sussex Fire and Rescue Service  
West Sussex County Council**

**Horsham Fire Station, Hurst Road, Horsham, West Sussex RH12 2DN.**

**Mobile: 07912 298433 or Phone BFS: 033022 23333 Email: [businessfiresafety@westsussex.gov.uk](mailto:businessfiresafety@westsussex.gov.uk)**

**Further Information: West Sussex County Council: [Business Fire Safety](#)**

**Do you know anyone that would benefit from a Home Fire Safety Check?**

**If so, please click here [West Sussex County Council: Home Fire Safety Checks](#)**



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.