

Date	Time	Address (Redacted)	Stored Cold Water Type (Haropack/Fortic/N/A)	Standing Pressure (Bar) *Picture	Working Pressure 1 Outlet Open (Bar) *Picture	Bathroom supply type (Mains or Gravity). *Mains- working pressure/Flow to be taken with bathroom outlet running	Flow Rate (lpm) *Picture	Flow Rate Multipule outlets open if mains (lpm) *Picture	Stopcock Condition Survey *Picture (Good/Fair/Poor)	Comments/Notes
13/09/2021	17:20		Harlo Pack	1.5	1.5	Gravity	12.5	NA	Fair	
13/09/2021	07:40		Harlo Pack	2	0.75	Mains-0	19	7	Good	
13/09/2021	17:40		Harlo Pack	0.9	0	Gravity	7	NA	Fair	
14/09/2021	07:00		Harlo Pack	2.2	1	Gravity	12	NA	Good	
14/09/2021	07:20		Fortic	0.8	0	Mains-0	5	0	Good	When all outlets are open, kitchen sink doesn't run.
14/09/2021	07:40		Harlo Pack	1	NA	Gravity	5.5	NA	Good	
14/09/2021	17:20		Harlo Pack	1.3	0.25	Gravity	15	NA	Good	
14/09/2021	17:40		Harlo Pack	2.75	1.9	Gravity	13	NA	Fair	
14/09/2021	18:00		Harlo Pack	1.4	0.3	Gravity	14	NA	Fair	
15/09/2021	07:20		Fortic	1.8	1	Mains-0.25	11	0.25	Poor	
15/09/2021	07:40		Harlo Pack	1	0.1	Gravity	9	NA	Poor	
15/09/2021	17:20		Fortic	2	0.4	Mains-0	13	8	Good	
15/09/2021	17:40		Fortic	1.25	0.3	Mains-0	6	5	Good	
15/09/2021	18:00		Harlo Pack	1.3	0.3	Gravity	14	NA	Good	
16/09/2021	07:20		Harlo Pack	1.9	1.9	Gravity	22	NA	Good	
16/09/2021	07:40		Harlo Pack	2.5	NA	Gravity	24	NA	Fair	Unable to connect the washing machine and stopcock is stiff
16/09/2021	17:30		N/A	2.3	1.3	Mains 1.1	19	16	Good	
16/09/2021	17:40		N/A	2.6	2.4	Mains 0.7	18	10	Good	
16/09/2021	18:00		Harlo Pack	1.9	NA	Gravity	21	NA	Good	Only able to connect at kitchen sink
17/09/2021	07:20		N/A	1.9	1	Mains 0.1	12	4	Good	
17/09/2021	07:40		N/A	2.3	2	Mains 0.9	11	7	Good	
17/09/2021	17:20		Fortic	1.25	0.3	Mains 0	13	9	Good	
17/09/2021	17:40		Harlo Pack	NA	NA	Gravity	8	NA	Good	Unable to check pressure as not accessible
21/09/2021	17:20		Harlo Pack	1.75	0	Gravity	6	NA	Good	
21/09/2021	17:40		Fortic	2	1.1	Mains 0.5	23	17	Fair	
22/09/2021	17:20		N/A	2.2	1.7	Mains 2	12	3	Poor	
22/09/2021	17:40		Harlo Pack	2	0	Gravity	6	NA	Fair	
22/09/2021	18:00		N/A	0.9	0.9	Mains	4	0	Good	No water comes out of kitchen tap when the bathroom outlet is on

23/09/2021	07:40		Harlo Pack	N/A	N/A	Gravity	24	NA	Fair	
23/09/2021	17:20		Harlo Pack	2.25	1.5	Gravity	12	NA	Fair	
23/09/2021	17:40		Harlo Pack	N/A	N/A	Gravity	9	NA	Good	Unable to connect to mains
23/09/2021	18:00		Harlo Pack	2	N/A	Gravity	14	NA	Poor	
24/09/2021	17:40		N/A	2.1	0.25	Mains-0	18	4	Poor	